

Annexure C

Appendix-XIII

CERTIFICATE SAFE DRINKING WATER AND SANITARY CONDITION

Dated: 27/06/2026

No: - TC-14194-2600002438F

It is certified that an inspection team headed by Naveen Suri (SAMPLING ASSISTANT) (Name of Officers with designation) from UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY inspected BASUBARAL SARASWATI VIHAR, APNA GHAR PARISAR, BISALPUR ROAD, BAREILLY, UTTAR PRADESH on 27/06/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. LAB/BLY/2026-27/2438 dated 25.06.2026 Of UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab) certified that BASUBARAL SARASWATI VIHAR, APNA GHAR PARISAR, BISALPUR ROAD, BAREILLY, UTTAR PRADESH has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid from 27-06-2026 to 26-06-2027.

Signature with Seal:

Name : RUMAN SAGHIR

Designation: (AE)

Name & Address of the Office / Department- UP JAL NIGAM BAREILLY (RURAL).

To
MANAGER

BASUBARAL SARASWATI VIHAR,
APNA GHAR PARISAR, BISALPUR ROAD,
BAREILLY, UTTAR PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Ruman Saghir
Principal
Basubaral Saraswati Vihar
Affiliated To C.B.S.E., Delhi
Bisalpur Road, Bareilly.





Analysis Report

District Level Water Analysis Laboratory (U.P. Jal Nigam)
(RURAL)

Near M.P. Inter College, Gonda Nagar, Bareilly (U.P.)



TC-14194

ULR No :- TC-14194-26000002438F

Customer Details

Office Name and Address :

BASUBARAL SARASWATI VIHAR, BISALPUR ROAD, BAREILLY.

Ref Letter No & Date :

NA.

DATE - 25-06-2026

Report No.- LAB/BLY/2026-27/2438

Basic details of sample

District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	25-06-2026
Village/AREA	BISALPUR ROAD	Block	-		
Habitation	APNA GHAR PARISAR	Location	BASUBARAL SARASWATI VIHAR	Analysis Completion Date	25-06-2026
Water Source	RO	Sample Code	PS- 2438		
Quantity of Sample	1 ltr	Date of Sample Collection	25-06-2026	Report Issue Date	25-06-2026
Receiving Date	25-06-2026	Sample Collector (Lab)	VIPIN KUMAR	Sample Depositor	PRAMOD KUMAR
Water Source	SOURCE IS NOT VERIFIED BY LABORATORY.				

Sampling Method - IS:17614 (Part-1:2021)

Environmental Condition

Temperature

25°C ± 3°C

Humidity

55% ± 20%

Technical Data of Analysis

S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(CU)	0	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-8):2023
4	Turbidity	(NTU)	0.09	1.00	5.00	IS 3025 (Part 10) : 2023
5	TDS	(mg/L)	210	500	2000	IS 3025 (Part 16) : 2023
6	PH	-	7.60	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
7	Iron	(mg/L)	-	1.00	1.00	IS:3025(Part-53):2024
8	Sulphate	(mg/L)	-	200	400	IS 3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	198	200	600	IS 3025 (Part 23) : 2023
10	Hardness	(mg/L)	174	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	10	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	61.6	75	200	IS:3025(Part-40):2024
13	Magnesium	(mg/L)	4.86	30	100	APHA 23 Edition 3500Mg Method B
14	Fluoride	(mg/L)	0.018	1	1.5	IS:3025 (Part-60):2023

Page no:-1/1

Email - anamika05anu@gmail.com
U.P.J.N.BAREILLY (RURAL) Contact No:- 7318253216

Anamika
Authorized signatory

END OF THE REPORT

Principal
Basubaral Saraswati Vihar
(Affiliated To C.B.S.E., Delhi)
Bisalpur Road, Bareilly



Scanned with OKEN Scanner